

NOTES:

- CONCRETE shall be Class 560-0-3250.
- 2. CURVATURE of the lip and sidewalls at the opening shall be formed by curved forms and shall not be made by plastering.
- 3. DIMENSIONS:

W shall be as specified on the plan (4! min.)

L shall be as specified on the plan.

V shall be as specified on the plan.

D = 4'6" unless otherwise specified on the plan.

t = 6" if V is 4' or less.

t = 8" if V is between 4' and 8'.

 $t = 10^{4}$ if V is 8' or more.

- CHANNEL shall be constructed in catch basins having inlet pipes. Where V minus shelf height is less than 21 the channel may be omitted. See Standard Drawing No. 405 for channel detail.
- 5. STEP SPACING

If V is 3.5' or less, no steps are required. If V is more than 3.5' and not more than 4', install one

step 12" above the floor.

If V is more than 4', install steps 12" apart with the top step 20" to 24" below the top surface of the basin. When the basin has a channel use V minus shelf height to determine step spacing.

- 6. PIPES shall be trimmed to the final shape and length before concrete is poured.
- SURFACE of all exposed concrete in basin shall conform in slope, 7. grade, color, finish and scoring to existing or proposed curb and walk adjacent to the basin and shall be free from protruding wires and nails. Floor of channel shall be given a steel-troweled finish.
- 8. TOP OF BASIN shall slope 2% toward curb except when otherwise shown on the plan or to fit existing sidewalk. To be poured monolithic with S/W if curb S/W is used.
- FRAME AND COVER shall be located as shown on sheet 1 unless otherwise shown on the plan.

APPROVED FOR WORKS DIRECTOR - R.C.E. 18793_				CITY OF RIVERSIDE PUBLIC WORKS DEPT ENGINEERING DIV.
<u>(1)</u>	Concrete Class Revision	wag . 8	3.25.80	CATCH BASIN
MARK	REVISIONS	APPR.	DATE	STANDARD DRAWING NO. 408